

**BEFORE THE STATE CORPORATION COMMISSION
OF THE STATE OF KANSAS**

In the Matter of Westar Energy Inc. and Kansas)
Gas and Electric Co. and Kansas City Power &) Docket No. 19-WSEE-011-CPL
Light Company, Compliance Filing Pursuant to)
Commission Order in Docket No. 15-WSEE-211-COM)

NOTICE OF COMPLIANCE

COME NOW Evergy Metro, Inc. d/b/a Evergy Kansas Metro [f/k/a Kansas City Power & Light Company] (“Evergy Kansas Metro”), Evergy Kansas Central, Inc. [f/k/a Westar Energy, Inc.] and Evergy Kansas South, Inc. [f/k/a Kansas Gas and Electric Company] (collectively referred to herein as “Evergy Kansas Central”);” and all three collectively referred to herein as “Companies”¹, and pursuant to the State Corporation Commission of the State of Kansas (“Commission”) Order issued in Docket No. 15-WSEE-211-COM on April 5, 2018 (“Order”), state as follows:

1. Ordering Paragraph D (p. 17) of the Order states:

Westar and KCP&L shall (1) annually complete and file a report of any structural fires claiming fault of the utility equipment, including all information and documentation not subject to attorney-client privilege; (2) include temperature sensor equipment with the installation of all Smart Meters not already in inventory; and, (3) use a go/no go tool to test meter base quality during routine testing, meter change out, and when the temperature alert is triggered.

2. In compliance with subsection (1) of the above-referenced paragraph, the Companies submit the attached **CONFIDENTIAL Attachment 1**.

WHEREFORE, the Companies that the Commission take notice of their compliance with the Order.

¹ Effective October 8, 2019, Evergy Metro, Inc. d/b/a Evergy Kansas Metro adopted the service territory and tariffs of KCP&L; *Order Approving Name Change*, Docket No. 20-KCPE-122-CCN, dated October 8, 2019. Effective October 8, 2019, Evergy Kansas Central, Inc. and Evergy Kansas South, Inc. d/b/a collectively as Evergy Kansas Central adopted the service territory and tariffs of Westar; *Order Approving Name Change*, Docket No. 20-WSEE-123-CCN, dated October 8, 2019.

Respectfully submitted,

/s/ Roger W. Steiner

Robert J. Hack (#12826)
Telephone: (816) 556-2791
Roger W. Steiner (#26159)
Telephone: (816) 556-2314
Evergy, Inc.
One Kansas City Place
1200 Main Street – 16th Floor
Kansas City, Missouri 64105
Facsimile: (816) 556-2787
E-mail: rob.hack@evergy.com
E-mail: roger.steiner@evergy.com

/s/ Cathryn J. Dinges

Cathryn J. Dinges, (#20848)
Phone: (785) 575-8344
Evergy, Inc.
818 South Kansas Avenue
Topeka, Kansas 66612
Facsimile: (785) 575-8136
E-mail: cathryn.dinges@evergy.com

**Attorneys Evergy Kansas Metro and
Evergy Kansas Central**

CERTIFICATE OF SERVICE

I do hereby certify that a true and correct copy of the foregoing document has been emailed or mailed, postage prepaid, this 28th day of February 2020, to all counsel of record, as listed below:

JOSEPH R. ASTRAB, ATTORNEY
CITIZENS' UTILITY RATEPAYER BOARD
1500 SW ARROWHEAD RD
TOPEKA, KS 66604
j.astrab@curb.kansas.gov

DELLA SMITH
CITIZENS' UTILITY RATEPAYER BOARD
1500 SW ARROWHEAD RD
TOPEKA, KS 66604
d.smith@curb.kansas.gov

TODD E. LOVE, ATTORNEY
CITIZENS' UTILITY RATEPAYER BOARD
1500 SW ARROWHEAD RD
TOPEKA, KS 66604
t.love@curb.kansas.gov

CATHRYN J. DINGES, CORPORATE
COUNSEL
EVERGY KANSAS CENTRAL, INC
818 S KANSAS AVE
PO BOX 889
TOPEKA, KS 66601-0889
Cathy.Dinges@evergy.com

DAVID W. NICKEL, CONSUMER
COUNSEL
CITIZENS' UTILITY RATEPAYER BOARD
1500 SW ARROWHEAD RD
TOPEKA, KS 66604
D.NICKEL@CURB.KANSAS.GOV

ROGER W. STEINER, CORPORATE
COUNSEL
EVERGY METRO, INC D/B/A EVERGY
KANSAS METRO
ONE KANSAS CITY PL, 1200 MAIN ST
19TH FLOOR
KANSAS CITY, MO 64105
roger.steiner@kcpl.com

SHONDA RABB
CITIZENS' UTILITY RATEPAYER BOARD
1500 SW ARROWHEAD RD
TOPEKA, KS 66604
s.rabb@curb.kansas.gov

ROBERT VINCENT, LITIGATION
COUNSEL
KANSAS CORPORATION COMMISSION
1500 SW ARROWHEAD RD
TOPEKA, KS 66604
r.vincent@kcc.ks.gov

/s/ Roger W. Steiner

Attorney for Evergy Kansas Metro and
Evergy Kansas Central

Evergy Metro Claims:

Claimant	DOL	Location	Description	Equipment Involved	Amount of Claim	Status
** [REDACTED] **	1/31/19	** [REDACTED] **	Allegations that tree fell on power line, causing electricity to surge and ignite a fire in customer's home	OH lines	** [REDACTED] **	Open – Subrogation claim received from insurer

Evergy Kansas Central Claims:

Claimant	DOL	Location	Description	Equipment Involved	Amount of Claim	Status
** [REDACTED] **	9/30/19	** [REDACTED] *	Customer alleges that Evergy Kansas Central lines caused house fire	Service line & ground wire	Unknown	Open – Notice of subrogation claim received from insurance company
** [REDACTED] *	3/21/2019	** [REDACTED] *	* [REDACTED] * claiming damage to grass when an explosion on the line caused a fire around the pole. Sent claim form.	Power line	Unknown	Open
** [REDACTED] **	1/13/2019	** [REDACTED] **	Limb fell on line. Caused fire where TV cable line attached at house. WESTAR NOT LIABLE. No claim filed to date.	Fire caused by a cable box	** [REDACTED] **	Open
** [REDACTED] **	5/25/2019	** [REDACTED] **	Damage to vehicle from an explosion of Westar's equipment.	Lightning arrestors/squirrel	** [REDACTED] **	Closed

** [REDACTED] **	6/13/2019	** [REDACTED] **	Cover on primary caught fire due to tree contact. Burning cover dropped on vehicle, set bed liner on fire.	Cover on primary	Unknown	Closed
** [REDACTED] **	8/15/2019	** [REDACTED] *	Customer outage and line was brought back on. Broken pole found afterwards resulting in round bale of hay catching fire. No damage to anybody. Property damage only.	Pole/power lines	Unknown	Closed
** [REDACTED] **	11/9/2019	** [REDACTED] **	Transformer lines came down and caused sparks/arcing. Found charred squirrel at bottom. Sparks caught fence on fire. Wants to file a claim for damages.	Transformer	Unknown	Open
N/A	11/12/2019	** [REDACTED] **	Grass fire, wire down. 3 poles South of * [REDACTED] ** Unknown, proactive report.	Power line	Unknown	Closed

** [REDACTED] **	11/16/2019	** [REDACTED] *	Damage to fence from fire. A switch failed behind ** [REDACTED] **, caught pole on fire. Due to dry and windy conditions, grass caught on fire in customer's yard. Chain link fence laying over.	Failed switch	Unknown	Open
** [REDACTED] *	11/30/2019	** [REDACTED] **	* [REDACTED] * called to see about cleanup from garage fire.	Unknown	Unknown	Open
N/A	12/26/2019	** [REDACTED] *	Cross arm at ** [REDACTED] ** broke due to normal wear and caused grass fire.	Broken cross arm	Unknown	Closed