

**BEFORE THE STATE CORPORATION COMMISSION** MAY 02 2005  
**OF THE STATE OF KANSAS**

*Susan K. Duffy* Docket Room

---

**DIRECT TESTIMONY**  
**OF**  
**DOUGLAS J. HENRY**  
**WESTAR ENERGY**

---

**DOCKET NO.** \_\_\_\_\_

---

**I. INTRODUCTION**

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13

**Q. PLEASE STATE YOUR NAME AND BUSINESS ADDRESS.**

A. Douglas J. Henry, 777 West Central, Wichita, Kansas 67202.

**Q. BY WHOM AND IN WHAT CAPACITY ARE YOU EMPLOYED?**

A. Westar Energy, Inc., Vice President, Power Delivery.

**Q. WHAT ARE YOUR RESPONSIBILITIES?**

A. I direct Westar's power delivery functions, commonly referred to as the "wires business." Power delivery encompasses electric transmission and distribution throughout Westar's service territory and involves transmission and distribution engineering, planning, dispatch, construction and maintenance. I am also responsible for technical services and administrative functions that support power delivery.

1       **Q.   PLEASE DESCRIBE YOUR EDUCATIONAL BACKGROUND**  
2       **AND PROFESSIONAL EXPERIENCE.**

3       A.   I have been in the utility business 30 years, since graduating from  
4       the University of Missouri-Rolla in 1975 with a BS in Electrical  
5       Engineering.  After serving approximately two years as a staff  
6       engineer with Oklahoma Gas and Electric Company in Oklahoma  
7       City, I began work with Kansas Gas and Electric Company (KG&E)  
8       in January 1977 as a staff engineer.  I have held numerous  
9       management jobs since 1979 in both transmission and distribution  
10      operations and engineering including serving as KG&E's Chief  
11      Engineer (1986-1992) and Director-Wichita Operations (1992-  
12      1996), Westar's Executive Director-Transmission & Distribution  
13      Engineering and Operations (1996-98), and VP-Power Delivery  
14      (1998-2001; 2003 to present).  I resigned from Westar on  
15      November 1, 2001 and returned on May 1, 2003 at the request of  
16      Messrs. Haines and Moore.

17      **Q.   WHAT IS THE PURPOSE OF YOUR TESTIMONY?**

18      A.   My testimony identifies and discusses our efforts to improve the  
19      reliability of Westar's transmission and distribution system.  As part  
20      of that discussion, I provide historical information on reliability-  
21      related expenditures and reliability performance.  Specifically, my  
22      testimony tracks reliability-related expenditures since 1998 and  
23      includes figures showing reliability performance results for the

1 period 2000 through 2004. Looking to the future, I discuss our  
2 2004-2008 five-year reliability goals, our major reliability initiatives,  
3 and the associated cost estimates to implement those initiatives. I  
4 also support the inclusion of certain service quality measures in our  
5 Reliability-Based Sharing Proposal.

## 6 II. RELIABILITY

7 **Q. PLEASE IDENTIFY THE MAJOR INITIATIVES UNDERTAKEN**  
8 **BY WESTAR ENERGY IN RECENT YEARS TO IMPROVE**  
9 **RELIABILITY OF THE TRANSMISSION AND DISTRIBUTION**  
10 **SYSTEM.**

11 A. In 1997, subsequent to the merger and integration of The Kansas  
12 Power and Light Company and KG&E, Westar, under my direction,  
13 commenced a program to place increased emphasis on improving  
14 the reliability of our transmission system. We initially focused on  
15 transmission reliability because both failures and improvements in  
16 our transmission system can be expected to have the greatest  
17 impact on the largest number of our customers. Components of  
18 this program included expanded right of way clearance efforts, 230  
19 kV AAAC (all aluminum alloy conductor) mitigation, EHV (extra high  
20 voltage) line terminal relay replacement and replacement of older  
21 substation equipment.

22 In 1998, the Power Delivery business unit was formed. This  
23 enhanced our ability to better plan and manage our reliability

1 programs more efficiently and cohesively on a total transmission  
2 and distribution system-wide basis. For example, Power Delivery  
3 has been responsible for overseeing a large expansion in Westar's  
4 vegetation management/distribution line clearance program that  
5 began in 1999. The improvements are dramatic. From 1999  
6 through 2004, the annual line clearance miles for under 25 kV lines  
7 increased from 570 miles to 1,855 miles while the number of  
8 clearance miles for 34 kV lines increased from 0 to 381 miles. Our  
9 34 kV line clearance is currently on a four-year cycle.

10 Combining distribution operations into one group has also  
11 allowed us to be more efficient with our programs. For example,  
12 during this same period (1999-2004), Westar's average cost per  
13 mile for distribution line clearance dropped from approximately  
14 \$14,000 to \$6,000 due to the centralization of line clearance  
15 management that occurred in 1999 and other process  
16 improvements we implemented. An independent assessment of  
17 our vegetation management program noted that between 1998 and  
18 2003 Westar had increased the number of miles of circuits that  
19 have been completely cleared by nearly 400 percent, with a 96  
20 percent increase in expenditures. There are additional  
21 opportunities to improve the efficiency of our vegetation  
22 management/line clearance program.



1           In 1998, we initiated enhanced equipment replacement and  
2           substation refurbishment programs, while continuing to expand our  
3           line clearance efforts. Items included expansion of our SCADA  
4           system, 12 kV breaker replacements, and 34 kV circuit  
5           refurbishment.

6           In 2003, we developed a comprehensive five-year strategic  
7           reliability plan. Outputs of the plan include performance targets for  
8           the period 2004-2008 and the identification and prioritization of  
9           reliability initiatives.


10       **Q. HAS WESTAR INCREASED FUNDING FOR SYSTEM**  
11       **RELIABILITY?**

12       A. Yes. Figure 1 below shows Westar's Capital and O&M  
13       expenditures for system reliability for the period 1998 through 2004  
14       as well as for the 2005 budget. The annual combined Capital and  
15       O & M reliability expenditures increased from \$14.4 million in 1998  
16       to \$33.5 million in 2004. The 2005 budget for these expenditures is  
17       \$37.6 million. Underscoring Westar's commitment to improve  
18       system reliability, a major increment of the increase in expenditures  
19       occurred during a time when, as the Commission knows, Westar  
20       was in the process of paying down substantial debt. The  
21       expenditures identified on Figure 1 as "Five Year Plan" for 2003-  
22       2004 and the 2005 budget include both Capital and O & M

1  
2  
3

expenditures related specifically to implementation of our five-year plan.

**FIGURE 1**



4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15

**Q. WAS FUNDING FOR VEGETATION MANAGEMENT/LINE CLEARANCE INCREASED IN THE 1998 THROUGH 2004 TIME FRAME?**

A. Yes. Trees growing in and near our lines are among the leading causes of service interruptions. Therefore, a substantial portion of the reliability-related funding increase was directed toward an enhanced vegetation management/line clearance program. Reflective of this increase, in 1998 our transmission and distribution O & M line clearance expenditures were \$7.89 million. By 2004, our O & M expenditures for line clearance had increased to \$18.77 million. Over the last seven years, we have expended approximately \$93.8 million for line clearance O & M costs alone.

1                   The magnitude and importance of this program is driven by  
2                   the size of our transmission and distribution system. It includes  
3                   4,400 transmission structure miles and nearly 22,053 distribution  
4                   overhead pole miles.

5                   **Q.    UPON WHAT PRIMARY INDICATORS DOES WESTAR RELY TO**  
6                   **MEASURE RELIABILITY PERFORMANCE?**

7                   A.    We believe that three primary reliability indicators are important and  
8                   they are included in our 2004-2008 five-year plan goals. They are  
9                   the System Average Interruption Frequency Index (SAIFI), the  
10                  System Average Interruption Duration Index (SAIDI), and  
11                  Customers Experiencing Multiple Interruptions (CEMI).

12                  **Q.    WHAT IS SAIFI?**

13                  A.    SAIFI reflects the annual average frequency of sustained  
14                  interruptions per customer. SAIFI is calculated by dividing the total  
15                  number of sustained customer interruptions (greater than five  
16                  minutes) by the total number of customers served. Our first and  
17                  most important reliability objective is to prevent interruptions.  
18                  Accordingly, reducing SAIFI has a high priority as we develop our  
19                  reliability plans and determine where funding should be directed.

20                  **Q.    WHAT IS SAIDI?**

21                  A.    SAIDI reflects the annual average time customers are interrupted.  
22                  It is calculated by dividing the sum of customer interruption  
23                  durations by the total number of customers served.

1       **Q.    WHAT IS CEMI?**

2       A.   CEMI represents the total number of customers that experience a  
3       certain number of sustained interruptions in a given year.  Since  
4       2002, we have measured CEMI-11 premises, which is the number  
5       of customers experiencing 12 or more sustained interruptions  
6       annually.

7       **Q.    DO THESE INDICES INCLUDE ALL EVENTS OR ARE MAJOR  
8       STORM EVENTS EXCLUDED?**

9       A.   Although each of these indices can be calculated to include all  
10      events, it is common practice to segment separately the minutes  
11      and interruptions that result from major system events.  We  
12      designate as a major event one that exceeds reasonable design  
13      and/or operational limits of the electric power system and is out of  
14      our control.  A recent example of such an event was the January 4,  
15      2005 ice storm.  The indices calculated with major system events  
16      removed are considered "normalized."  Westar utilizes normalized  
17      indicators for trending, goal setting, and programming functions as  
18      well as benchmarking results between utilities.

19      **Q.    CAN MORE THAN ONE METHOD BE USED FOR  
20      NORMALIZATION?**

21      A.   Yes.  In Westar's case, there are three methods that need to be  
22      discussed.  First, prior to 2005, we historically used a methodology  
23      that required: (a) restoration time from a storm event to be at least

1 24 hours, (b) the assistance of crews outside the affected serving  
2 office to restore service; and (c) the Customer Average Interruption  
3 Duration Index (CAIDI) for the storm event to be at least 2.5 times  
4 the normal monthly CAIDI for the affected servicing office.

5 Second, in 2005, we adopted the normalization standard  
6 method developed by The Institute of Electrical and Electronic  
7 Engineers (IEEE), commonly referred to as IEEE-1366 2003.  
8 Under IEEE-1366 2003, a major event day is defined as a day in  
9 which the daily SAIDI exceeds a threshold derived statistically from  
10 the company's historical daily SAIDI results for the prior five years.

11 Third, in its Service Quality Docket, the Commission adopted  
12 what is commonly referred to as "the 10% rule." This rule defines a  
13 major event to be "a catastrophic event caused by forces exceeding  
14 the design limits required by codes and regulations, and  
15 characterized by extensive damage to the electric power system  
16 and sustained interruptions to more than 10% of a utility's  
17 customers within a 24 hour period." Docket No. 02-GIME-365-GIE,  
18 Electric Reliability Requirements, par. 3(n). Even though the  
19 Commission adopted this methodology in the Service Quality  
20 Docket, it also invited the utilities to report results using IEEE-1366  
21 2003, and indicated a willingness to reconsider IEEE-1366 2003 at  
22 a later time after more statistical history has been accumulated.

1       **Q.    WHAT NORMALIZATION METHODOLOGY DID YOU USE TO**  
2       **DETERMINE YOUR FIVE-YEAR GOALS?**

3       A.    Our 2004-2008 five-year plan annual goals were originally  
4       determined using Westar's historic methodology described above.  
5       As I testified earlier, the five-year plan was developed in 2003 and  
6       we relied on the historic methodology until 2005. The statistical  
7       results from this methodology were sufficiently close to those  
8       obtained from applying the IEEE-1336 2003 methodology to allow  
9       us to retain the original plan goals even though we have made the  
10      internal shift to IEEE-1366 2003.

11      **Q.    WHAT NORMALIZATION METHODOLOGY HAVE YOU USED IN**  
12      **THIS PROCEEDING?**

13      A.    We used the IEEE-1366 2003 normalization methodology to  
14      develop the SAIFI and SAIDI data utilized by Mr. Fitzpatrick in  
15      determining the performance targets to be used for those two  
16      measures in our Reliability-Based Sharing Proposal. We did so  
17      because, as I noted above, the IEEE-1366 2003 methodology is  
18      now used for managing our reliability program. We believe it  
19      provides a sound basis for measuring performance and reviewing  
20      effectiveness. On a going forward basis, it will also furnish a more  
21      accurate and consistent method for benchmarking our reliability  
22      performance to that of other utilities.

1       **Q.    DOES THE NORMALIZATION METHODOLOGY HAVE AN**  
2       **IMPACT ON THE RELIABILITY-BASED SHARING PROPOSAL?**


3       A.    Yes.    The average performance indicators and deadbands  
4       described in Mr. Fitzpatrick's testimony would vary depending upon  
5       the methodology used.  I believe that using IEEE-1366 2003  
6       provides a tighter, more focused approach than the 10% rule.  
7       Regardless of the methodology employed, however, it must be  
8       used consistently throughout the evaluation process, i.e., the same  
9       normalization methodology must be used to establish the annual  
10      targets and bandwidths and to measure actual results.

11      **Q.    PLEASE DESCRIBE WESTAR'S HISTORICAL PERFORMANCE**  
12      **UNDER THE SAIFI, SAIDI AND CEMI INDICATORS.**

13      A.    I have prepared Figures that display results for each of the three  
14      indicators as well as our 2004-2008 five-year goals.  Figure 2  
15      shows normalized data for SAIFI for the period 2000-2004 and our  
16      five-year goals.  Figure 3 reflects normalized SAIDI data for the  
17      same period.  Figure 4 displays normalized CEMI-11 premise count  
18      results for the same period.  Again, I would note that the SAIFI and  
19      SAIDI indicators shown in these tables have been normalized using  
20      the IEEE-1366 2003 method.


1

FIGURE 2 – SAIFI



2


FIGURE 3 – SAIDI





1

**FIGURE 4 – CEMI-11**



2

**Q. DO THE FIGURES SHOW ANY TRENDS IN WESTAR'S RELIABILITY PERFORMANCE?**

3

4

A. Recognizing that the results in any one year are likely to be affected by weather events that are not so severe as to be normalized, but still have significant impact on our system, I think it is clear that the trend for the years 2000 through 2004 reflects improvement. This is particularly true for the CEMI-11 premise count where the number of premises experiencing 12 or more sustained interruptions in a year declined precipitously from 1,652 in 2000 to 170 in 2004.

5

6

7

8

9

10

11

1       **Q.    WHAT ARE WESTAR'S SAIFI, SAIDI, AND CEMI 2008**  
2       **PERFORMANCE GOALS?**

3       A.    As shown in Figures 2 through 4, our 2008 goals for these  
4       indicators are:

- 5       •     Reduce SAIFI by approximately 30 percent from the 2002  
6           result to a normalized level of 1.25 interruptions per  
7           customer per year. In 2002, our SAIFI index was 1.72. In  
8           2004, the index was down to 1.37.
- 9       •     Reduce SAIDI by approximately 40 percent from the 2002  
10          result to a normalized interruption duration period of 106  
11          minutes. In 2002, our SAIDI index was 170 minutes. In  
12          2004, the index was down to 117 minutes.
- 13      •     Reduce CEMI-11, the number of premises experiencing 12  
14          or more sustained interruptions per year, to zero.

15      **Q.    WHAT HAS PROMPTED WESTAR'S EFFORTS TO FURTHER**  
16      **IMPROVE SERVICE RELIABILITY?**

17      A.    We take seriously our mission to provide safe, reliable, high quality  
18      electric energy service at a reasonable cost to our customers. The  
19      customer satisfaction surveys we have conducted over the last two  
20      years (2003-2004) give us generally high marks for reliability and  
21      service quality. Nevertheless, we recognize that there are  
22      significant opportunities for improvement to reduce both the  
23      frequency and duration of service interruptions.

1                   There are also good reasons to believe that customers will  
2 be expecting more reliable power supplies in the future than in the  
3 past. As the electric industry has improved over the years,  
4 customers' expectations for higher levels of reliability in electric  
5 service have increased. Our customers, like those throughout the  
6 United States, are more dependent than ever on reliable supplies of  
7 electricity for business and household needs. The growing and  
8 pervasive use of computers in homes and businesses is one  
9 important factor contributing to the need for increased reliability.  
10 Power interruptions can lead to a loss of computer output and  
11 productivity with attendant costs and frustrations for customers.

12       **Q.   ON WHAT BASIS DID WESTAR DETERMINE THE FIVE-YEAR**  
13       **PERFORMANCE GOALS THAT YOU HAVE IDENTIFIED?**

14       A.   With respect to CEMI-11, we believe it is appropriate to eliminate  
15 excessive service interruptions as part of our mission to be a  
16 reliable electric energy supplier. We have already made significant  
17 progress toward this goal and we are determined to meet the goal.  
18 In fact, in 2005, we have started tracking CEMI-9, in addition to  
19 CEMI-11. Meeting the SAIFI and SAIDI goals will result in  
20 performance levels that are better than average for electric utilities  
21 in the United States for these performance indicators,  
22 notwithstanding the large size and rural nature of much of our  
23 service territory.

1       **Q.    WHAT FACTORS WILL INFLUENCE YOUR EFFORTS TO**  
2       **REACH YOUR PERFORMANCE GOALS?**

3       A.    I have already identified the occurrence of localized weather events  
4       that are not normalized as an important factor that can influence  
5       our performance.  Another important factor will be our ability to  
6       direct sufficient funding to reliability-related projects between now  
7       and 2008.  As I have discussed, we have already increased  
8       reliability funding significantly since 1998 with a major increase  
9       occurring in 2004.  The 2004 combined Capital and O & M  
10      reliability-related funding was \$33.5 million.  As I previously noted,  
11      our budget for 2005 is \$37.6 million.  However, current projections  
12      indicate that an additional \$12.75 million in combined Capital and O  
13      & M funding is needed annually to achieve our 2008 goals.  I  
14      recognize that these are aggressive goals and we will be  
15      challenged to meet and sustain them.

16                 The outcome of this rate review will impact our ability to fund  
17      our reliability-related projects.  Whatever funding ultimately is  
18      available, we have made and demonstrated a strong commitment  
19      to our reliability programs.  It is our intent to implement program  
20      efficiencies and to prioritize expenditures in ways that will maximize  
21      our reliability performance.

1       **Q.    IN ADDITION TO WEATHER AND FUNDING, ARE YOU AWARE**  
2       **OF OTHER FACTORS THAT MAY AFFECT WESTAR'S**  
3       **RELIABILITY PERFORMANCE?**

4       A.    Yes. Our infrastructure is aging. Thirty-one percent (31%) of our  
5       poles have been in service for over 40 years. Forty-five percent  
6       (45%) of our distribution substation transformers are also over 40  
7       years old. The age of these plant components will increasingly  
8       affect reliability and most likely result in higher annual costs for  
9       plant repair and replacement than we have historically experienced.

10       An analogy comes to mind. My wife and I once owned a  
11       house that was nearly 40 years old. In addition to replacing  
12       shorter-lived things like water heaters and the like, we were also  
13       faced with larger issues such as re-building the front porch and  
14       driveway, completely refurbishing the HVAC system, and jacking up  
15       the foundation to eliminate the effects of years of settling. These  
16       expenditures were required to continue to maintain and use the  
17       asset we owned. We are concerned about the onset of similar  
18       needs with our T&D system as it continues to grow older. At some  
19       point in time, it is likely that much greater funding will be required to  
20       maintain the level of service required by our customers and the  
21       Commission, which we want to provide. We want to be in a  
22       financial position that allows us to make necessary expenditures to  
23       meet and maintain our 2008 reliability goals.

1       **Q.     PLEASE DESCRIBE THE MAJOR RELIABILITY INITIATIVES**  
2       **PLANNED BY WESTAR.**

3       A.     In 2003, under my direction, Westar initiated a strategic planning  
4       process to identify, prioritize, and estimate costs of programs that  
5       could improve the reliability of our systems over a five-year period.  
6       The original plan was reviewed in late 2004 by two independent  
7       consultants, Environmental Consultants, Inc. and Davies  
8       Consulting, Inc. Both found the 2003 plan to be sound and based  
9       on good utility practices. However, working with our employees,  
10      several recommendations for program improvements are under  
11      review. Major efforts that we are now implementing include:

- 12               •     continued centralized focus on and enhancement of  
13               our vegetation management program (including  
14               distribution tree trimming, transmission rights-of-way  
15               clearance, herbicide treatments, etc.);
- 16               •     conducting visual and infrared inspections on worst-  
17               performing equipment failed circuits (infrared senses  
18               heat emanating from damaged electric equipment and  
19               hence signals needed repair work before failure  
20               occurs);
- 21               •     a multi-year plan to improve and update fuse  
22               coordination for distribution circuits (fuse coordination

- 1 minimizes the impact of an interruption by confining  
2 the area affected to as small an area as possible);
- 3 • refurbishment of distribution substations and feeders;
  - 4 and
  - 5 • reducing the number of customers experiencing a  
6 high number of sustained interruptions.

7 We have also undertaken other less costly, but, nonetheless,  
8 important initiatives. They include such things as improving the  
9 quality of field incident coding, developing standards for best  
10 practices to improve lightning protection, and upgrading the  
11 standards for installing animal protection.

12 **Q. WESTAR HAS OFFERED A RELIABILITY-BASED SHARING**  
13 **PROPOSAL THAT INCORPORATES SERVICE QUALITY**  
14 **INDICATORS. IS IT REASONABLE TO INCLUDE SUCH**  
15 **INDICATORS IN A PERFORMANCE BASED PLAN?**

16 A. Yes. As I have discussed, our customers are increasingly  
17 dependent on receiving reliable electricity service and we are  
18 committed to meeting that need. I know that the Commission is  
19 also concerned that Kansas retail electric customers are provided  
20 reliable service. Including service quality indicators in the  
21 Reliability-Based Sharing Proposal is one reasonable way to  
22 underscore the importance that the Commission and we place on  
23 ensuring and improving service quality and reliability.

1       **Q.    THE WESTAR RELIABILITY-BASED SHARING PROPOSAL**  
2       **UTILIZES SAIFI AND SAIDI AS TWO OF THE FIVE SERVICE**  
3       **QUALITY PERFORMANCE INDICATORS. IS IT REASONABLE**  
4       **TO INCLUDE SUCH INDICATORS IN A PERFORMANCE-BASED**  
5       **PLAN?**

6       A.    Yes. SAIFI is a good reliability measure because it measures how  
7       often customers on our system experience supply interruptions.  
8       The incidence of a power interruption can immediately impose  
9       inconveniences on our customers. As I have previously testified,  
10      we endeavor to minimize the number of interruptions that our  
11      customers experience. Including a SAIFI measure in our  
12      Reliability-Based Sharing Proposal promotes this important goal.

13               SAIDI is a particularly important reliability indicator because  
14      it combines the effects of both the number of customers interrupted  
15      and the duration of sustained interruptions. Customer welfare  
16      depends not only on whether an interruption occurs, but how long it  
17      lasts. Customer well being clearly diminishes as the duration of  
18      power interruptions increases. We must attempt to restore power  
19      supplies quickly once an interruption occurs.

20               SAIFI and SAIDI are the comprehensive industry-accepted  
21      indicators of service reliability. Since these indicators are  
22      measured system-wide, they reflect all sustained interruptions  
23      experienced by customers on our transmission and distribution



1 systems. I believe that a service quality performance plan should  
2 be applicable to all customer classes. The use of SAIFI and SAIDI  
3 is consistent with that objective because they take into account the  
4 reliability of service to all customers.

5 **Q. WHY IS IT APPROPRIATE THAT PERFORMANCE MEASURES**  
6 **BE NORMALIZED RATHER THAN USING ACTUAL**  
7 **PERFORMANCE DATA?**

8 A. As I discussed previously, we have normalized these measures for  
9 certain external influences, such as periods of severe weather that  
10 are beyond our control. In any incentive plan, it is important for  
11 rewards and penalties to reflect a company's real performance  
12 rather than factors beyond its control.

13 **Q. IS WESTAR'S RELIABILITY DATA AFFECTED BY OTHER**  
14 **FACTORS THAT ARE NOT ACCOUNTED FOR IN THE**  
15 **NORMALIZATION PROCESS?**

16 A. Yes. As I have previously noted, even after our SAIFI and SAIDI  
17 data are normalized to separately account for the effects of severe  
18 weather and related events that lead to widespread interruptions in  
19 our service territory, these indicators typically vary from year to year  
20 because of factors beyond our control. The most important of  
21 these factors is weather. Lightning, high winds and storms that are  
22 not severe enough to meet the normalization criteria are major  
23 causes of supply interruptions. Our SAIDI and SAIFI data would

1 vary, for example, if in one year we had a dozen non-normalized  
2 storms and in the next we experienced half a dozen. Mr. Fitzpatrick  
3 has evaluated these natural phenomena and has estimated that  
4 these variables have a short-term impact of at least 50% of the  
5 normally occurring yearly variance. Of course, these weather  
6 factors fluctuate from year to year and cannot be predicted with  
7 confidence in advance. Therefore, even the normalized SAIFI and  
8 SAIDI data can be affected, to a significant extent, by  
9 circumstances that are beyond our control. This is one reason why  
10 it is appropriate to use bandwidths and ranges of performance  
11 instead of point estimates.

12 **Q. ARE THERE DIFFERENCES IN OBSERVED SAIFI AND SAIDI**  
13 **BETWEEN ELECTRIC COMPANIES?**

14 A. Yes.

15 **Q. WHAT FACTORS MAY CAUSE SUCH DIFFERENCES?**

16 A. Differences in these indices between utilities can result from factors  
17 specific to each electric utility's service territory. Such differences  
18 may not reflect real, underlying differences in the reliability of the  
19 electric companies' services. For instance, it is common for rural  
20 territories to register higher values for SAIDI than urban areas.  
21 This occurs because customers are served with longer feeders that  
22 are more exposed to the elements and it normally takes more time  
23 for crews to respond to interruptions in rural areas because

1 customers are in more remote locations. This tends to increase the  
2 duration of interruptions.

3 **Q. SHOULD SEPARATE SAIFI AND SAIDI RELIABILITY**  
4 **MEASURES BE APPLIED TO THE WESTAR ENERGY NORTH**  
5 **AND SOUTH SERVICE TERRITORIES?**


6 A. No. While there are differences in the make-up of the two service  
7 territories, the differences are not so great as to require separate  
8 reliability measures. Moreover, we have centralized reliability  
9 planning and management, applied our reliability goals across our  
10 transmission and distribution systems, and directed the  
11 development and execution of our reliability programs toward  
12 achieving uniformity and consistency across our service territories.  
13 We believe that one SAIFI indicator and one SAIDI indicator should  
14 be applied across our system.

15 **III. 2002 AND 2005 ICE STORMS**

16 **Q. MR. KONGS IS SPONSORING AN ADJUSTMENT TO RECOVER**  
17 **THE COSTS ASSOCIATED WITH THE DAMAGE CAUSED BY**  
18 **TWO ICE STORMS. CAN YOU PLEASE DESCRIBE THE**  
19 **OPERATIONAL AND FINANCIAL BASIS FOR THIS**  
20 **ADJUSTMENT?**

21 A. Our operations suffered severe damage from two extraordinary  
22 storms. The first occurred in January 2002 and the second in  
23 January 2005. What makes this circumstance particularly unusual

1 is our having experienced two similar storms of such magnitude  
2 within a few years of one another. Figure 5, which shows a  
3 comparison of customer outage minutes caused by major storms in  
4 our service territory, graphically demonstrates the impact and



5 severity of the ice storms.

6 **FIGURE 4**

7 **Q. WHEN WAS THE LAST TIME WESTAR EXPERIENCED**  
8 **DAMAGE OF THE MAGNITUDE CAUSED BY THE 2005**  
9 **STORM?**

10 **A.** Never. The 2005 ice storm is the most damaging storm in the  
11 history of Westar North and South. There are other instances of  
12 extraordinary storm damage, however, for which similar treatment

1 has been deemed appropriate. For example, KPL sought and the  
2 Commission granted an accounting order to preserve for recovery  
3 costs from an extraordinarily severe ice storm that occurred in  
4 March 1984 – 21 years ago.

5 **Q. HOW HAVE YOU TREATED THESE STORMS FROM A**  
6 **BOOKKEEPING PERSPECTIVE?**

7 A. The portion of the restoration that qualified as capital expenditures  
8 were booked to plant in the ordinary course. For the portion of the  
9 restoration expenditures that qualify as maintenance expense, we  
10 applied a two-step process. First, for Westar South, in accordance  
11 with Commission order, we charged \$4.1 million of this expense  
12 against the existing storm reserve. For the expenses beyond this  
13 level we sought and received the Commission's authority to defer  
14 these expenditures as a regulatory asset for future recovery. This  
15 rate review provides the first opportunity for Westar to begin  
16 recovering these costs.

17 **Q. STORMS ARE PART OF KANSAS. HOW DO YOU BUDGET FOR**  
18 **THE COSTS OF STORM DAMAGE?**

19 A. We include funding for some degree of storm damage in our routine  
20 maintenance budgets. In addition, and as I've already alluded to,  
21 we maintain a storm reserve account where we accrue expenses in  
22 expectation of having future storm damage of a magnitude we  
23 would consider to be greater than routine. We have a clear,

1 established protocol as to when storm damage is severe enough  
2 where it warrants charging the related expenses to that reserve.  
3 The annual amounts for both of these are part of our cost of  
4 service. Neither of these provisions, however, is sufficient or was  
5 intended to address the cost of storm damage of the magnitude  
6 associated with either of the subject ice storms.

7 **Q. WHY CAN'T YOU ESTABLISH A RESERVE FOR THIS LEVEL**  
8 **OF CONTEMPLATED DAMAGE?**

9 A. We could, but I believe we would be doing our customers a  
10 disservice. To do so would run the risk of asking customers to pay  
11 for an accrual in their rates that would build up reserves we may  
12 never need in their lifetimes. At the very least, an annual storm  
13 accrual of such magnitude would run a high risk of being unfair to  
14 present customers.

15 **Q. CAN YOU PURCHASE COST-EFFECTIVE INSURANCE FOR**  
16 **THIS KIND OF DAMAGE?**

17 A. No. We have studied that possibility. We found that there were  
18 very few potential providers. Further, the coverage would require  
19 such high deductibles and high annual premiums that it would be  
20 an unwise expenditure.

21 **Q. DOES THE FEDERAL EMERGENCY MANAGEMENT**  
22 **AUTHORITY PROVIDE FINANCIAL ASSISTANCE TO UTILITIES**

1           **LIKE WESTAR FOLLOWING STORM DAMAGE OF THIS**  
2           **MAGNITUDE?**

3           A.    No.    FEMA provides financial assistance of various types to  
4           smaller, usually cooperatively or publicly owned utilities, but not to  
5           larger investor-owned utilities like Westar.


6           **Q.    HAVE YOU ALREADY BRIEFED THE COMMISSION STAFF ON**  
7           **THE NATURE OF THE DAMAGE AND WESTAR'S STORM**  
8           **RESTORATION EFFORTS?**

9           A.    Yes.  On February 11 of this year we met with Staff and others to  
10          brief them on the nature of the storm and the massive restoration  
11          effort it required.  Attached to my testimony as Exhibit \_\_\_\_ (DH-1)  
12          is a copy of that briefing document.  Exhibit \_\_\_\_ (DH-2) is a copy of  
13          the presentation we made to the Commission regarding the 2002  
14          ice storm.

15          **Q.    THANK YOU.**

# Westar Energy Ice Storm Report January 4-5, 2005

Presented  
February 11, 2005






# January '05 Ice Storm




# January '05 Ice Storm




# January '05 Ice Storm




# January '05 Ice Storm




# January '05 Ice Storm



# January '05 Ice Storm




# January '05 Ice Storm





# January '05 Ice Storm






# January '05 Ice Storm




January '05 Ice Storm



# January '05 Ice Storm



# January '05 Ice Storm




# January '05 Ice Storm





# January '05 Ice Storm



## January '05 Ice Storm


- ◆ January 3 - the first wave of ice affects 6,500 customers - all restored by 11:00 pm
- ◆ January 4/5 - 18 hours of freezing rain over most of south central Kansas, Emporia, and the Topeka-to-Olathe areas
  - Ice accumulation ranged from 0.25-1.0 inch (radial)
- ◆ Weather facilitated repairs on some days but hampered repairs on most
- ◆ January 12 – service restored to 99% of affected customers
- ◆ January 14 - service completely restored after working approximately 372,000 man-hours
- ◆ Worst storm in Westar's history

## January '05 Ice Storm

- ◆ 720 million customer minutes of interruption
- ◆ 369,000 total outages restored, with many customers experiencing numerous outages due to multiple system failures as the ice continued to accumulate
- ◆ 261,000 customers affected (40% of company total)
  - Significant damage in Wichita, Newton, El Dorado and Emporia Divisions
  - 60% or 156,000 Wichita customers affected
  - Nearly all of Newton Division off at least once
- ◆ Highest number of customers affected at any one time – 146,000
- ◆ Customer contact center handled 368,000 calls
  - 104,000 on the first day - normally 5,000 to 10,000 daily
- ◆ \$38 to \$42 million price tag



# January '05 Ice Storm




# January '05 Ice Storm Summary

**January 4th Ice Storm  
Number of Customers Affected  
By Substation**

**Outages**

- 1000 - 2000
- 2001 - 3000
- 3001 - 4000
- 4001 - 5000
- 5001 - 6000
- 6001 - 7000
- 7001 - 8000
- 8001 - 9000



## January '05 Ice Storm

---

- ◆ Communities affected by distribution and/or transmission circuit lockouts:
  - **Arkansas City Division:** Arkansas City, Atlanta, Burden, Cambridge, Dexter, Douglass, Geuda Springs, New Salem and Parkerfield
  - **El Dorado Division:** Benton, Burns, El Dorado, Elbing, Latham, Leon, Potwin, Towanda and Whitewater
  - **Emporia Division:** Admire, Allen, Benedict, Bushong, Cassoday, Coyville, Elmdale, Emporia, Eureka, Fall River, Olpe and Toronto
  - **Hutchinson Division:** Buhler, Nickerson, Pretty Prairie and Hutchinson
  - **Lawrence Division:** Lawrence, Lecompton and Linwood
  - **Leavenworth Region:** Atchison, Lancaster, McLouth, Oskaloosa, Valley Falls, Bonner Springs, Everest, Hiawatha, Lansing, Basehor and Leavenworth

## January '05 Ice Storm

- ◆ Communities affected continued:
  - **Newton Division:** Burrton, Walton, Goessel, Halstead, Hesston, Haven, Mt Hope, Sedgwick, Cedar Point, Florence, North Newton, Peabody and Newton
  - **Southeast Kansas Region:** Elk Falls, Grenola, Howard, Longton and Moline
  - **Salina Region:** Durham, Lincolnville, Lost Springs, Parkerville, Ramona, Tampa, Galva, Canton and Lehigh
  - **Topeka Division:** Berryton, Carbondale, Eskridge, Harveyville, Meriden, Overbrook and Topeka
  - **Wichita Division:** Andale, Andover, Derby, Haysville, Bel Aire, Belle Plaine, Cheney, Colwich, Garden Plain, Goddard, Rose Hill, Udall and Wichita

## January '05 Ice Storm

---

- ◆ Affected system elements:
  - Transmission circuits – 20
  - Substation equipment failures - 5
  - Distribution circuits – 231
  - Primary/secondary spans down - 5,000
  - Services repaired – 27,429
  - Poles replaced – 982
  - Laterals refused – 3,000
  - Transformers refused – 5,600
  - Transformers replaced - 499

## January '05 Ice Storm

- ◆ Largest storm repair workforce ever assembled at Westar
- ◆ Involved 3,513 workers
  - 976 Westar employees
    - Line Personnel - 324
    - Contact Center - 112
    - Dispatch - 39
    - Support - 380
    - Management - 108
    - Retirees and former employees - 13
  - 1361 line personnel from other utilities and contractors
  - 1176 line clearance personnel
- ◆ Aid came from Nebraska, Texas, Missouri, Oklahoma, Colorado, Kentucky, Tennessee, West Virginia, New Mexico, Wyoming, Illinois, Iowa, Indiana, South Dakota, Minnesota, Michigan and Louisiana

## January '05 Ice Storm

- ◆ Estimating a total cost of \$38 to \$42 million
  - Maintenance = \$31 to \$34 million
  - Construction = \$7 to \$8 million
  
- ◆ Last major event, '02 ice storm, had a price tag of \$20 million
  - Maintenance = \$13 million
  - Construction = \$7 million


## January '05 Ice Storm

- ◆ Fully utilized Westar Energy's storm procedures
  
- ◆ Corporate Crisis Center opened at noon on Tuesday, January 4, and immediately began to coordinate resources and information
  - Operational until Thursday, January 13
  
- ◆ Crisis Center's primary role:
  - Secure additional manpower and material
  - Coordinate crew comfort issues
  - Assemble and distribute information
  - Prioritize work between affected areas
  - Remove as many obstacles as possible for local storm managers




# January '05 Ice Storm


## Storm Crisis Center



# January '05 Ice Storm




# January '05 Ice Storm



## January '05 Ice Storm


- ◆ Zone concept utilized in Wichita and Newton
- ◆ Wichita zones were established based on zip codes
- ◆ Each zone manager responsible for:
  - Safety and system operating procedures
  - Damage assessment
  - Material needs
  - Repair crew assignments
- ◆ Started in zones with most customers off and moved to new zones as manpower became available

# January '05 Ice Storm



- 50,000 of the customers affected in Wichita were in zones 1-5.


# January '05 Ice Storm



# January '05 Ice Storm




# January '05 Ice Storm





# January '05 Ice Storm



## January '05 Ice Storm

- ◆ Crew comfort and community support
  - Hyatt prepared 800 breakfasts, box lunches and dinners each day
  - Refreshments and meals were constantly delivered to the field
  - Workers filled every available hotel room in Wichita, Newton and El Dorado
  - Some workers were transported by bus from hotels in outlying areas
  - Customers fed personnel on many occasions
  
- ◆ Great support from vendors providing material
  - Neighboring utilities provided needed materials
  - One material order flown in from Mexico/Texas

# January '05 Ice Storm



# January '05 Ice Storm




# January '05 Ice Storm




## January '05 Ice Storm



# January '05 Ice Storm



# January '05 Ice Storm






## January '05 Ice Storm

- ◆ Automated outage reporting system received widespread use
- ◆ Communications to customers and media were effective
- ◆ Provided customers with estimated restoration times
- ◆ Affected life support customers were contacted at least twice
- ◆ Visits to corporate web site were almost 3 times normal
- ◆ Kept media apprised of challenges and progress - held 2 news conferences (January 7 and 11)

# January '05 Ice Storm




**Number still without power continues to fall as Westar Energy, partnering crews complete work in many areas**

Updated 4 p.m. Wednesday, Jan. 12, 2005


As of 4 p.m., about 1,550 customers remained without power. Below is a list of Westar Energy divisions and the outages in those areas. (numbers are rounded)

- Wichita, 970
- Newton, 520
- El Dorado, 65


Electric crews have completed outage restoration work in the zones shown in green. In zones shown in red, work on primary lines is complete, and crews have turned their attention to the service lines that serve individual homes and businesses. Work on primary lines remains under way in the zones shown in blue.



# January '05 Ice Storm



# January '05 Ice Storm




IF CARTOONISTS HAD TO WORK, STRAPPED TO A UTILITY POLE IN SUBFREEZING WEATHER LIKE A WESTAR LINEMAN...


## January '05 Ice Storm

---

- ◆ Power was restored in 10 days, but much work remained
  - 99% complete in 8 days
- ◆ Many customers were waiting for electricians to make repairs
  - 544 permanent repairs completed since January 14
- ◆ Facilities fixed by temporary means, to quickly restore service to customers, still needed a permanent fix
  - Wichita personnel back to normal hours February 7
- ◆ Extra contract line and tree crews remained in Wichita assisting with clean up and the backlog of normal work
  - All released by January 31 to normal duty



# Comparison of Storms Total Customer Outage Minutes



# Cost Estimate

- Total Estimated Cost:     \$20,459,953
- O&M Cost:             \$13,206,544
- Construction Cost:    \$ 7,253,409



# Summary

## ■ Category

|                               |         |
|-------------------------------|---------|
| – Pole Miles Outaged          | 5020    |
| – Dist. Circuit Lockouts      | 240     |
| – #Poles Down (Dist.)         | 1,022   |
| – #Structures Down (Trans)    | 57      |
| – #Spans Primary Down         | 1,650   |
| – #Services Down              | 3,200   |
| – Total Customers Affected    | 104,393 |
| – Transmission Lines Affected | 14      |
| – 21st Century Calls          | 86,781  |
| – Restoration Personnel       | 1,370   |

# Transmission Damage

- 69kV Lines
  - 11 poles, Numerous Crossarms
  - 2 switches
- 115kV Lines
  - 1 Line down, no failed structures
- 138kV
  - 15 Steel Lattice Structures
- 345kV Lines
  - 31 Structures
- Fiber Optic Communication System
  - 3 Breaks due to Transmission structure damage

# Crew/Equipment Summary

## ■ Manpower


- #Tree Crews/People 153/400
- #Line Crews/People 214/690 (Crews: Westar 105,Utility 65,Contractor 44)
- #Phone Center 80
- #Misc. Support 200 (Crisis Center, Assessment & Support Teams)

## ■ Equipment

- 138 Service Trucks
- 119 Bucket Trucks
- 121 Diggers
- 10 Pressure Diggers
- 12 Caterpillars/Dozers
- 2 Helicopters
- 1 Airplane

Outside Crews from Kansas, Indiana, Colorado, Iowa, Nebraska, Arkansas, Illinois, Oklahoma, Missouri & South Dakota

# Weather Maps - 1/30/02 10:25AM




Start Time: Wednesday 9:00 AM CST  
Expires Time: Thursday 9:00 AM CST  
Conditions: Snow  
Comments: Heavy snow will fall across central and west-central KS through dawn CT Thursday morning. The heaviest snow will fall tonight but accumulating snow will begin after dawn CT. Snowfall rates up to 2.0 in will occur.

Start Time: Tuesday 9:30 PM CST  
Expires Time: Wednesday 2:15 PM CST  
Conditions: Ice  
Comments: Heavy, Summer, Cowley, Elk, Chautauque, Woodson, Wilson, Montgomery, Allen, Nessho, Labette Counties. Freezing rain will develop tonight, continuing through Wednesday afternoon. Ice accumulations of 1/4-1/2 inch are expected by Wednesday afternoon. We will issue a new warning Wednesday afternoon with accumulation updates.

Start Time: Wednesday 7:00 AM CST  
Expires Time: Wednesday 9:00 PM CST  
Conditions: Ice  
Comments: Light to moderate freezing rain and sleet will fall across south-central Kansas, including the city of Wichita, through dawn tonight, from 10 to 25% of ice accumulation is expected in the next 24 hours. Periods of freezing rain will occur. This warning expires 0018.



# Weather Maps - 1/30/02 7:04PM



UPDATED - UPDATED - UPDATED - UPDATED


Start Time: Wednesday 6:11 PM CST  
Expire Time: Thursday 8:30 AM CST

Conditions:  
Ice

Comments:  
UPDATE for SOUTHEAST KS. Northeast winds are increasing to 15 to 20 mph, with the freezing rain on trees, the risk of damage is increasing with the winds. We forecast a 1 to 1.25" of ice from freezing rain from Greentown, Co. east Butler, Co. westward. A rain/snow mix break can be expected.

| Area | Temperature | Wind | Time |
|------|-------------|------|------|
| 1    | 13          | 10   | 10P  |
| 2    | 13          | 10   | 10P  |
| 3    | 13          | 10   | 10P  |
| 4    | 13          | 10   | 10P  |
| 5    | 13          | 10   | 10P  |
| 6    | 13          | 10   | 10P  |
| 7    | 13          | 10   | 10P  |
| 8    | 13          | 10   | 10P  |
| 9    | 13          | 10   | 10P  |
| 10   | 13          | 10   | 10P  |
| 11   | 13          | 10   | 10P  |
| 12   | 13          | 10   | 10P  |
| 13   | 13          | 10   | 10P  |
| 14   | 13          | 10   | 10P  |
| 15   | 13          | 10   | 10P  |
| 16   | 13          | 10   | 10P  |
| 17   | 13          | 10   | 10P  |
| 18   | 13          | 10   | 10P  |
| 19   | 13          | 10   | 10P  |
| 20   | 13          | 10   | 10P  |
| 21   | 13          | 10   | 10P  |
| 22   | 13          | 10   | 10P  |
| 23   | 13          | 10   | 10P  |
| 24   | 13          | 10   | 10P  |
| 25   | 13          | 10   | 10P  |
| 26   | 13          | 10   | 10P  |
| 27   | 13          | 10   | 10P  |
| 28   | 13          | 10   | 10P  |
| 29   | 13          | 10   | 10P  |
| 30   | 13          | 10   | 10P  |
| 31   | 13          | 10   | 10P  |
| 32   | 13          | 10   | 10P  |
| 33   | 13          | 10   | 10P  |
| 34   | 13          | 10   | 10P  |
| 35   | 13          | 10   | 10P  |
| 36   | 13          | 10   | 10P  |
| 37   | 13          | 10   | 10P  |
| 38   | 13          | 10   | 10P  |
| 39   | 13          | 10   | 10P  |
| 40   | 13          | 10   | 10P  |
| 41   | 13          | 10   | 10P  |
| 42   | 13          | 10   | 10P  |
| 43   | 13          | 10   | 10P  |
| 44   | 13          | 10   | 10P  |
| 45   | 13          | 10   | 10P  |
| 46   | 13          | 10   | 10P  |
| 47   | 13          | 10   | 10P  |
| 48   | 13          | 10   | 10P  |
| 49   | 13          | 10   | 10P  |
| 50   | 13          | 10   | 10P  |
| 51   | 13          | 10   | 10P  |
| 52   | 13          | 10   | 10P  |
| 53   | 13          | 10   | 10P  |
| 54   | 13          | 10   | 10P  |
| 55   | 13          | 10   | 10P  |
| 56   | 13          | 10   | 10P  |
| 57   | 13          | 10   | 10P  |
| 58   | 13          | 10   | 10P  |
| 59   | 13          | 10   | 10P  |
| 60   | 13          | 10   | 10P  |
| 61   | 13          | 10   | 10P  |
| 62   | 13          | 10   | 10P  |
| 63   | 13          | 10   | 10P  |
| 64   | 13          | 10   | 10P  |
| 65   | 13          | 10   | 10P  |
| 66   | 13          | 10   | 10P  |
| 67   | 13          | 10   | 10P  |
| 68   | 13          | 10   | 10P  |
| 69   | 13          | 10   | 10P  |
| 70   | 13          | 10   | 10P  |
| 71   | 13          | 10   | 10P  |
| 72   | 13          | 10   | 10P  |
| 73   | 13          | 10   | 10P  |
| 74   | 13          | 10   | 10P  |
| 75   | 13          | 10   | 10P  |
| 76   | 13          | 10   | 10P  |
| 77   | 13          | 10   | 10P  |
| 78   | 13          | 10   | 10P  |
| 79   | 13          | 10   | 10P  |
| 80   | 13          | 10   | 10P  |
| 81   | 13          | 10   | 10P  |
| 82   | 13          | 10   | 10P  |
| 83   | 13          | 10   | 10P  |
| 84   | 13          | 10   | 10P  |
| 85   | 13          | 10   | 10P  |
| 86   | 13          | 10   | 10P  |
| 87   | 13          | 10   | 10P  |
| 88   | 13          | 10   | 10P  |
| 89   | 13          | 10   | 10P  |
| 90   | 13          | 10   | 10P  |
| 91   | 13          | 10   | 10P  |
| 92   | 13          | 10   | 10P  |
| 93   | 13          | 10   | 10P  |
| 94   | 13          | 10   | 10P  |
| 95   | 13          | 10   | 10P  |
| 96   | 13          | 10   | 10P  |
| 97   | 13          | 10   | 10P  |
| 98   | 13          | 10   | 10P  |
| 99   | 13          | 10   | 10P  |
| 100  | 13          | 10   | 10P  |



weather data



# Pictures




# Pictures







# Pictures




# Pictures



# Pictures




# Pictures



# Pictures



# Pictures



# January 30th to February 6th Ice Storm Trouble Order Storm Summary - Total Customers REMAINING OUT

